

Chapter 23

Electrical Safety

February 1996

Approved by the ES&H Working Group

_____ date _____
Robert Kuckuck
Deputy Director for Operations

23

Electrical Safety

Contents

* 23.1	Introduction.....	23-1
23.2	Applicability.....	23-1
23.3	Requirements/Regulatory Summary.....	23-2
23.4	Methods for Reducing Risks.....	23-2
23.4.1	General.....	23-2
23.4.2	Electrical Equipment Conditions of Approval and Use.....	23-2
23.4.3	Work on Electrical Components and Systems.....	23-3
23.4.4	Clearances and Illumination for Electrical Enclosures.....	23-3
23.4.5	Temporary Wiring.....	23-4
23.4.6	Extension Cords/Multiple Outlet Boxes/Flexible Cords and Cables.....	23-5
23.4.7	Power Plugs and Receptacles.....	23-6
23.4.8	Ground-Fault Circuit Interrupters.....	23-7
23.4.9	Portable Electrical Tools, Equipment, and Instruments.....	23-7
23.4.10	Equipment Grounding.....	23-8
23.4.11	Static Electricity	23-8
23.4.12	Personal Protective Equipment.....	23-10
23.4.13	Reviews and Inspections	23-10
23.4.14	Emergency Assistance and Rescue.....	23-11
23.4.15	Analysis of Electrical Incidents.....	23-12
* 23.5	Responsibilities.....	23-12
23.5.1	Employees	23-12
23.5.2	Supervisors.....	23-12
23.5.3	Electrical Safety Advisory Board	23-12
23.6	Training.....	23-13
23.6.1	Electrical Workers	23-13
23.6.2	Non-Electrical Workers	23-14
23.6.3	Supplementary Training.....	23-14
23.7	LLNL Contacts.....	23-15
23.8	Supporting References and Standards.....	23-15
Appendix 23-A Terms and Definitions.....		23-17
Appendix 23-B Effects of Electrical Energy on Humans.....		23-23
Appendix 23-C Electrical Equipment Compliance Criteria.....		23-29

Electrical Safety

23.1 Introduction

Electricity is used in many different ways at LLNL. Each application has its own combination of risks which includes the potential of electric shock, fire, and burns. Thus, it is essential for all employees, including supplemental labor and subcontractor employees, to be aware of the hazards associated with electrical work and know how to use the appropriate protective methods to minimize the risk of an injury or accident.

This chapter contains policies, general guidance, and risk-reducing methods for work involving electrical equipment and systems. Appendix 23-A contains the terms and definitions used in this chapter; Appendix 23-B, the effects of electrical energy on humans; and Appendix 23-C, a list of references, regulations, Department of Energy (DOE) orders, and standards which give the criteria for the design, installation, acceptance, operation, and maintenance of electrical equipment. Supplement 23.01 (Work on Electrical Equipment, Power Distribution Premises Wiring, and Stationary Wiring) gives more specific guidance on electrical work.

In addition to the guidance provided in this chapter and in Supplement 23.01 for electrical work, Programs should consult the Electrical Safety Advisory Board (ESAB) as necessary for further guidance on electrical safety issues. The ESAB was chartered on February 20, 1996, and comprises a chair and several members from Hazards Control, Electronics Engineering, and Plant Engineering who are knowledgeable in electrical safety. The chair is a member of the Technical Support and Policy Development Division and is appointed by the Hazards Control Department Head. The other members are nominated by the chair and approved by the Hazards Control Department Head.

23.2 Applicability

The policies and guidance in this chapter apply to all operations involving operational and programmatic electrical work at LLNL and to all managers, designers, users, installers, and others who service or operate electrical equipment and systems—including R&D equipment and systems.

23.3 Requirements/Regulatory Summary

All electrical work performed at LLNL shall conform to the applicable codes and standards in Appendix 23-C. Where conflicts arise, the standard or code providing the greatest degree of safety shall be used.

Research and development (R&D) facilities must comply with the rules and regulations established by the Occupational Safety and Health Administration (OSHA), the American National Standards Institute (ANSI), and the National Fire Protection Association (NFPA), except as otherwise directed by the DOE. The DOE is the Authority Having Jurisdiction (AHJ) for enforcing electrical codes and regulations and the governmental body exercising legal jurisdiction over all electrical work at LLNL.

23.4 Methods for Reducing Risks

23.4.1 General

Only qualified and authorized individuals are permitted to perform electrical work at LLNL. A qualified person is one who has the required skills and knowledge to perform electrical work safely. Such individuals must be aware of the hazards associated with electrical work (see Appendix 23-B for details) and the methods for reducing the risk of electrical accidents that can result from unsafe equipment, adverse environmental conditions, and unsafe acts.

Whenever possible, all circuits or equipment shall be de-energized before beginning any work. Work on energized circuits shall only be performed by authorized persons, as described in Supplement 23.01. In addition, employees shall use

- Proper design, fabrication, installation, and documentation techniques.
- Proper operational and maintenance procedures.
- Electrical equipment approved by a nationally recognized testing laboratory (NRTL).
- Proper personnel protective equipment (PPE).

In support of Lab-wide electrical safety, management shall take a proactive approach when dealing with the root causes of employees' concerns, near-misses, and incidents or accidents involving electrical hazards.

23.4.2 Electrical Equipment Conditions of Approval and Use

All electrical equipment, components, and conductors should be listed, labeled, and approved by an NRTL for their intended purpose. Custom-made and installed equipment can be approved for use if built according to specific standards (e.g., Underwriters Laboratories [UL] 508 or one of the ANSI C series standards). Appropriate documentation for such equipment shall be maintained on file.

When building, repairing, or modifying electrical systems, NRTL-approved equipment must be used if available. Non-NRTL-approved equipment (e.g., shop-made extension cords) shall be built in accordance with an approved design.

23.4.3 Work on Electrical Components and Systems

Any live electrical parts should be positively de-energized when working on or near electrical circuits, equipment, or systems. Circuits and equipment must be considered energized until opened, locked and tagged out, and verified as de-energized using an approved testing device in accordance with Supplement 26.13 (LLNL Lockout and Tagout Program). Where it is possible for the circuits to be energized by another source, or where capacitor devices (including cables) may retain or build up a charge, circuits should be grounded and shorted. In addition, the following precautions shall be observed to improve safety in the workplace:

- Follow LLNL-established procedures (see Table A-1 of Appendix A in Supplement 23.01).
- Identify and report to supervision potential electrical hazards or unexpected occurrences or incidents (i.e., discharges or arcs when applying grounds to circuits thought to be de-energized), including near misses.
- Anticipate potential electrical problems and hazards.
- Do not rush to finish a job—never bypass approved policies and procedures.
- Plan and analyze for safety during each step of any electrical work.
- Keep accurate records (e.g., as-built designs) of all pertinent work performed on a project.
- Have significant safety-related work (e.g., work requiring an OSP) independently verified.
- Use properly rated test equipment and verify its condition and operation before and after use.
- Know applicable emergency procedures.

23.4.4 Clearances and Illumination for Electrical Enclosures

A clear working space shall be maintained in the front, back, and on each side of all electrical enclosures and around electrical equipment for safe operation and to permit access for maintenance and alteration. The documents listed below shall be referred to, as required (NOTE: The National Electric Code (NEC) is available from the Technical Information Department (TID) Library and the Plant Engineering Library. You may also contact Hazards Control for additional information on the NEC):

- NEC Article 110–16, “Clearance and entrance requirements on electrical equipment rated at 600 V nominal or less”
- NEC Article 110–32, “Work space requirements for electrical equipment rated at 600 V nominal or above”

- NEC Article 110–33, “Entrance and access to work space”
- NEC Article 110–34, “Work space and guarding requirements”
- Supplement 23.01, “Safe Work Practices for Electrical and Electronic Equipment and Utility and Facility Power Systems”

The *IES Lighting Handbook* (latest edition) specifies that adequate illumination shall be provided for all working spaces around electrical equipment, and that the control switches for light circuits shall be positioned away from exposed energized circuits and other potential electrical hazards.

23.4.5 Temporary Wiring

Construction Power and Lighting. Temporary wiring for electric power and lighting is permitted during periods of construction, remodeling, maintenance, repair, or demolition of equipment or structures, and during emergencies. Temporary wiring does not mean a “reduced” level of safety or quality because the wiring must still conform to certain criteria for electrical work. Temporary wiring shall have a temporary wiring tag attached with the following information:

- Review/approval and signature of the facility manager, area supervisor, lead experimenter, construction inspector, or Plant Engineering Electrician Shop supervisor and the signature of the appropriate ES&H team industrial safety representative.
- The reason for the temporary wiring (i.e., emergency, construction, test, and/or research and development).
- Installation date.
- Name, phone number, and pager number (if applicable) of the person installing the temporary wiring tag.

In addition, the temporary wiring

- Shall be approved or identified as suitable for installation and installed in accordance with the rules prescribed in the current edition of the NEC and 29 CFR 1910 and 1926.
- Shall be protected from accidental damage.
- Shall be removed as soon as the prescribed activity is completed. It shall not be used as a substitute for permanent wiring.
- Shall be color coded in accordance with Plant Engineering or Electronic Engineering standards.
- May be used during an “off-shift working hour” emergency. On the day of installation, a temporary wiring tag shall be completed and attached to the wiring so that it is readily visible. Approvals for the wiring tag must be obtained on the first regular work day after the emergency.

Switches or other means shall be installed to permit the disconnection of all ungrounded conductors of each temporary circuit. All lamps used for temporary illumination shall have a suitable fixture or a lamp holder with a guard to prevent damage or accidental contact with energized parts.

Experiments. Temporary wiring may be used for experimental and developmental equipment. There is no time limit on how long the wiring can remain in place, except that it must be removed upon completion of the experiment. Temporary wiring tags are not required for temporary wiring within experimental systems, but are required for the power feeder to the power distribution points of experimental systems. These wiring tags shall contain the same information as previously described.

23.4.6 Extension Cords/Multiple Outlet Boxes/Flexible Cords and Cables

Extension Cords. Observe the following precautions when using extension cords. Note that extension cords for normal office use do not require a temporary wiring tag.

- Use only three-wire extension cords and cables that conform to the rating, grounding, and non-interchangeability stated in NEC Article 210-7, "Receptacles and Cord Connectors."
- Check extension cords before use to ensure they are adequate for the intended purpose. Plug high-current equipment (e.g., space heaters, hot plates, and coffee pots) directly into a wall receptacle whenever possible.
- Use only one extension cord for lamps, appliances, or other equipment in conjunction with the power supply cord. Laboratory policy is to prohibit the use of multiple extension cords (daisy chaining) that will increase the resistance in an electrical circuit, which in turn will increase the heating of conductors, receptacles, and plugs.
- Inspect extension cords for damage before placing them in service and daily during use. Only qualified and authorized persons can repair extension cords; this must be done in a manner approved by the manufacturer. Replace damaged cords with ones listed by an NRTL. Contact the ES&H team for guidance, if necessary.
- For receptacles connected to circuits with different voltages, frequencies, or current (ac or dc) on the same premises, use a design such that the attachment plugs on the circuits are not interchangeable (see Section 23.4.7 for details). All extension cords stocked by Central Supply shall comply with ANSI C73.

Only high-visibility orange or yellow extension cords shall be used outdoors and with portable or integral ground-fault circuit interrupters (GFCIs).

Multiple Outlet Boxes. Observe the following precautions when using multiple outlet boxes:

- Each multiple outlet box shall be plugged into a wall receptacle. Use of one outlet box to provide power to one or more outlet boxes is not permitted.
- Outlet boxes shall not be used to provide power to space heaters, hot plates, coffee pots, or other high-current loads. These types of appliances have caused outlet boxes to burn up.

Note that multiple outlet boxes used in offices, including those with surge protection for computers, do not require a temporary wiring tag.

Flexible Cords and Cables. Flexible cords and cables shall comply with the requirements in NEC Article 400 (Flexible Cords and Cables). They shall not be

- Used as a substitute for fixed wiring of a structure.
- Attached to building surfaces.
- Routed through holes in walls, ceilings, or floors; or through doorways, windows, or similar openings.
- Concealed behind building walls, ceilings, or floors.
- Wired with a plug or connector that does not have dead-front construction or strain relief. “Dead-front construction” is defined as electrical equipment built so that it is “without live parts exposed to a person on the operations side of the equipment.”
- Placed where they could present a trip or fall hazard.
- Used when the cord insulation is damaged, cracked, or spliced; or when the ground pin is missing from the end of the male cord plug.
- Installed in raceways, except as otherwise permitted by the NEC.

Individual conductors of a flexible cord or cable shall not be smaller than those listed in Table 440-4 of NEC Article 400.

Article 240-4 of the NEC (Protection of Flexible Cords and Fixture Wires) states that flexible cords, including extension cords, shall be protected against overcurrent in accordance with their ampere ratings (see Tables 400-5(A) and 400-5(B)). NEC Article 400-14 states that flexible cords and cables inserted through holes in covers, outlet boxes, or similar enclosures shall be protected by bushings or fittings.

23.4.7 Power Plugs and Receptacles

The Laboratory uses many different voltages, frequencies, and current (ac or dc) in power systems and equipment. Thus, it is essential to ensure that such equipment cannot be inadvertently connected to the wrong power source. For specific purposes, voltage, and current ratings, use a plug or receptacle that fully complies with ANSI C73. See the configuration chart (from ANSI C73)

in the NFPA *National Electrical Handbook* for information on general-purpose locking and nonlocking plugs and connectors. Use of the National Electrical Manufacturers Association (NEMA) connectors may not be appropriate for all research and development applications. Contact Electronics Engineering Specifications and Standards Group for guidance, if necessary.

23.4.8 Ground-Fault Circuit Interrupters

Ground-fault circuit interrupters—either circuit breakers or portable ground-fault interrupting receptacles—shall be used for all 125-V, single-phase, 15-A and 20-A receptacles; for temporary wiring outdoors, and wherever employees will be using electrical equipment around water or in damp environments. Unlike fuses or standard circuit breakers, which are designed to protect equipment from overcurrent, GFCIs are designed to protect personnel from serious injury or death.

Article 305-6 of the NEC (Ground-Fault Protection for Personnel) requires GFCI protection for personnel and for temporary wiring where 125-V, single-phase, 15-A and 20-A receptacle outlets are in use and are not part of the permanent wiring for the structure. LLNL requires the use of GFCIs for any type of construction work to ensure personnel protection, even if the receptacle is part of the permanent wiring of the building.

Laboratory policy is to provide its employees and subcontractors with at least the same level of protection from electric shock as they would have in their own homes. NEC Article 210-8 (Ground-Fault Circuit-Interrupter Protection for Personnel) specifies that GFCIs must be installed in dwellings where 125-V, single-phase, 15-A and 20-A receptacles are installed outdoors; in bathrooms, garages, and crawl spaces at or below grade; in unfinished basements; and where receptacles on countertop surfaces are within 6 ft of a sink. Thus, all the aforementioned areas within LLNL shall have receptacles with GFCI protection.

Exceptions:

- In Laboratory areas where receptacles are required (other than on counter tops) to supply power to specific equipment (i.e., receptacles dedicated to refrigerators or other heavy equipment).
- Line filters and other power supply components in many electronic instruments are not designed to be connected to GFCI-protected circuits. These instruments draw sufficient capacitive current to trip a GFCI and shall not be installed in wet or damp locations.

23.4.9 Portable Electrical Tools, Equipment, and Instruments

Portable electrical equipment or tools shall always be inspected to identify defects; defective equipment shall be removed from service immediately. Portable electrical equipment shall be connected to a portable GFCI (or a circuit that contains a GFCI) when used outdoors, in damp locations, in any

unsafe environment, or for indoor or outdoor construction. Ordinarily, the casings for portable electrical equipment are grounded. If it is necessary to operate this type of equipment with other than a grounded equipment casing, suitable barriers, guards, or shields shall be installed to protect personnel while working on or near the equipment. In addition, a safety procedure shall be written describing the controls for safe operation of the equipment.

Receptacles and flexible cords can be used to connect electrical appliances and equipment (e.g., fans, machine tools, pumps) to power sources. Receptacles used on a two-wire, single-phase portable generator (or vehicle-mounted generator) with a rating of not more than 5 kW (where the circuit conductors are insulated from the frame and all other grounded surfaces) do not need to be GFCI protected.

23.4.10 Equipment Grounding

All electrical apparatus, equipment, and systems shall be grounded in accordance with NEC Article 250 (Grounding) and ANSI standards. The conductor used for grounding shall meet the following criteria:

- Be permanent and continuous.
- Facilitate operation of the circuit's protective devices.
- Have sufficiently low impedance to limit the voltage to ground to a safe level at all frequencies and fault-current conditions anticipated.
- Have the capacity (size and rating) to safely conduct any fault current that may be imposed on it for the time required for protective device operation.

Guidelines for proper grounding of programmatic equipment and systems can be found in the Electronics Engineering Department *Grounding Guidelines: Practical Examples for Power Systems at LLNL* (UCID-19752).

23.4.11 Static Electricity

A static charge is an imbalance of electrons on objects (matter) that can build up on all matter and transfer from one object to another by conduction or induction. The discharge of static electricity can cause shock or a fire or explosion. Although this type of shock is painful, it is not normally physically hazardous and therefore is not considered reportable as an electric shock. It should be noted, however, that injuries may result from the reaction to the shock (i.e., by a person rapidly pulling his/her hand away from a metal object and hitting an elbow against a wall or cabinet).

Equipment and Personnel Guidelines. When working with electrical equipment, employees shall follow the guidelines below for their own protection and that of the equipment:

- Grounding of the metal parts or enclosures will continuously discharge static. Therefore, wrist straps and other connections used to ground

employees shall be solidly grounded where static-safe workstations are used for semiconductor, electronic, or explosive work. Grounding prevents the wrist strap from becoming a shock hazard in the event of a short circuit from a voltage to the wrist-strap conductor.

- Bonding will equalize the potential between two adjacent noncurrent-carrying metal parts or enclosures. Thus, only approved or listed grounding clamps are acceptable for static bonding and grounding. Alligator clamps are not acceptable.
- Dust is attracted to the face of the video display terminal because of a static charge of approximately 25,000 V. Never clean the glass face of a computer monitor while the computer is on. When a person touches the screen with a finger, the charge in the portion of the screen touched discharges through the finger with a tiny spark. Electric current does not normally flow through glass, so only the part of the screen that the finger touches is discharged. When cleaning a monitor, however, the entire glass is wet and the charge on the entire screen will discharge to a finger or hand causing a much more painful shock.
- Never allow any electrical-powered office equipment to become wet while it is turned on, and never turn on any electronic equipment when it is wet. Even when a computer is turned off for a few minutes, it is best not to touch the monitor's CRT while handling or using other electronic equipment—including the telephone. Wet or dry, a person may receive an electric shock similar to one that can be received by touching a metallic object when vacuuming, machining a dielectric, or walking across carpeting in leather shoes.

NFPA Regulations for Fire and Lightning. NFPA 77 (Static Electricity) provides guidance on reducing the fire hazard of static electricity. Lightning, an example of static electricity, is covered in NFPA 78 (Lightning Protection Code). This document gives details on lightning protection requirements for ordinary facilities and facilities containing flammable vapors, gases, or liquids.

Flammable Vapor. A flammable vapor source can be ignited by static electricity if the following conditions exist simultaneously:

- Generation of a static charge imbalance.
- Static charge accumulation.
- Flammable atmosphere.
- A spark with significant ignition energy or temperature.

Liquids. Electrostatic charges can be generated by the movement of liquid through pipes, funnels, pumps, filters, or by free flowing through air. Static charges generated by flowing liquids can be reduced or eliminated by bonding or grounding, or both; by lowering the flow rate; or by reducing the amount of

misting, spraying, free-fall, and splashing of the liquid. Pay particular attention to situations where the liquid stream may impinge on a connection to a capacitor, high-voltage bushing, or cable terminal. Static charge from the liquid can store hazardous quantities of electrical energy in a capacitor over time. This hazard is most likely to occur when filling electronic apparatus tanks with insulating oil.

23.4.12 Personal Protective Equipment

Personal protective equipment is required when installing, examining, adjusting, servicing, fabricating, testing, or maintaining electrical equipment. Line management shall provide employees with the appropriate PPE, and the employee's supervisor shall ensure that the equipment is used properly. Alternatively, employees may contact the area ES&H team for assistance in selecting the appropriate PPE for the operation. Protective footwear; hard hats; and insulated, nonmetallic-framed safety glasses shall meet the requirements of ANSI Z41, ANSI Z87.1, and ANSI Z89.2 (see Table 23-1 below).

Rubber-insulated (nonconductive) protective equipment shall be visually inspected at the beginning of each work day before use and after performing work that can cause damage to PPE. This inspection shall include an air test of the gloves used. Hot sticks, grounds, aerial-lift equipment and booms, hot rope, and hot ladders shall also be visually inspected.

23.4.13 Reviews and Inspections

Major modifications to new and existing facilities and projects may be inspected by the DOE (or authorized designee) to verify compliance with codes and standards that are in effect on the day that such work is approved by a final design review. If the modification involves a hazard to life, equipment, or property, current safety policies shall be reviewed and used to mitigate the hazard.

Table 23-1. ASTM/ANSI standards for PPE.

Protective equipment or apparel	ASTM standard	ANSI standard
Rubber, insulating gloves	D 120	—
Rubber, insulating matting	D 178	—
Rubber, insulating blankets	D 1048	—
Rubber, insulating covers	D 1049	—
Rubber, insulating line hose	D 1050	—
Rubber, insulating sleeves	D 1051	—
Protective foot wear	—	Z41
Eye and face protection	—	Z87.1
Nonconductive hard hats (helmets)	—	Z89.2
Leather protectors for rubber insulating gloves	F 696	—

23.4.14 Emergency Assistance and Rescue

Anyone who experiences or witnesses an electric shock at the Livermore site or Site 300 that involves any of the four circumstances below shall immediately report the incident to the Fire Department Emergency Rescue (dial 911).

1. Obvious serious injury (e.g., loss of consciousness, significant trauma).
2. Altered mental status (e.g., confusion, slow/slurred speech).
3. Other obvious injury (e.g., laceration, muscle strain, burn).
4. At the discretion of the first responder making a judgment of the situation.

In addition, this individual shall

- Initiate cardiopulmonary resuscitation (CPR), if appropriate. (Only trained personnel should perform this task.)
- Have victims who do not meet the criteria to be transported by ambulance taken to Health Services for evaluation.
- Ensure that all potential sources of energy are safe and in a neutral state.
- Notify the victim's supervisor and the appropriate ES&H team as soon as possible. (The victim's supervisor and Hazards Control will want to determine what caused the electric shock.)
- Properly secure the area once the victim is under care, leaving items and equipment in the same position as much as possible. Try to remember the original position of items that may have been moved during response to the accident.
- Record the time, date, and location of the accident; the names of the victim and witnesses; who was notified; the voltage and current; the contact parts of the body; what equipment or system was being serviced; and the shock reaction and duration of the shock.

All LLNL employees, supplemental labor employees, and contract personnel who work with electrical equipment or systems should be trained in basic life support, including CPR. In the event of an obviously serious electric shock, properly trained first-response personnel should provide CPR to victims in cardiac and/or respiratory arrest until an LLNL paramedic arrives. This may reduce the risk of morbidity and mortality following a serious electric shock. The paramedic will then provide advanced cardiac life support until the victim arrives at the receiving hospital.

All other electric shock victims must be taken to Health Services for evaluation so that potentially damaging effects can be detected early and treated properly. It should be noted that such effects may not be immediately recognized and can appear later (see Appendix 23B for details).

23.4.15 Analysis of Electrical Incidents

Serious and potentially lethal incidents, including near-misses that could result in a serious or potentially lethal shock, shall undergo an incident analysis in accordance with Chapter 4 of the *Health & Safety Manual*. This analysis shall be determined by facility or Program management and the responsible ES&H team.

23.5. Responsibilities

23.5.1 Employees

Individuals assigned to electrical work shall only perform the tasks for which they are qualified. They shall

- Understand the basic principles of electricity and electrical safety.
- Follow applicable OSHA requirements.
- Use the proper tools and required PPE.
- Request additional training so that they do not work beyond their level of qualification or comfort.
- Comply with the requirements set forth by the DOE, OSHA, and LLNL.

23.5.2 Supervisors

Supervisors shall ensure that employees comply with the requirements set forth by the DOE, OSHA, LLNL, and other regulatory agencies; that PPE is available and employees use them appropriately; and that all employees are adequately qualified. They shall also determine the work each employee is qualified to perform and make work assignments accordingly.

23.5.3 Electrical Safety Advisory Board

The ESAB is the Laboratory's technical resource for electrical safety issues. The ESAB provides support primarily through the ES&H Teams, which are the initial point of contact for all safety issues raised by Programs or individuals. The Board is also responsible for the following:

- Identifying electrical safety hazards and making recommendations for resolution.
- Providing support to Programs' line management responsible for analyzing electrical accidents and incidents.
- Evaluating electrical accidents and incidents to determine trends.
- Developing, reviewing, and approving electrical safety training programs.
- Interacting on a continual basis with groups (e.g., ES&H Working Group and subcommittees, Directorate safety committees and councils, the ES&H Teams) charged with providing a safe work environment for employees. This interaction may include conducting electrical safety

presentations and providing a forum (e.g., written or electronic communication or meetings) for the exchange of ideas and information.

- Informing management and employees of lessons learned from electrical accidents and incidents.
- Participating in DOE electrical safety programs (e.g., DOE and EFCOG Electrical Safety Committees).

23.6. Training

23.6.1 Electrical Workers

Employees who perform electrical work shall be trained to recognize the hazards associated with their work environment and know how to minimize the risk of an accident or injury using appropriate procedures and protective equipment. Supervisors shall verify the qualifications and training of all electrical workers before they are permitted to perform electrical work. Training requirements are identified in the LLNL *Training Program Manual* and the directorate training implementation plans.

Employee training shall be documented with respect to the specific equipment and tasks for which the employee is qualified. Much of the experience required for an employee to be considered qualified is specific to the equipment and tasks involved. On-the-job training is always a necessary component of a qualification program. Classroom training, including courses offered by Hazards Control, is a useful way to ensure that employees share a common level of basic knowledge on which to build specific on-the-job training. Additionally, employees can gain knowledge and experience on how to perform their jobs safely and properly by taking courses offered by universities and trade schools or through apprenticeships, on-the-job training (OJT), or other formalized training. The depth of training and how training is provided shall be determined by the risks associated with the employee's respective tasks. The responsibility for ensuring that employees are qualified to perform their job rests with their supervisors.

Electrical workers shall be trained in and be familiar with the following, as appropriate:

- The safety-related work practices required by 29 CFR 1910, Subparts J and S; and 29 CFR 1926, Subparts K and V (see Section 8.0 for details).
- The skills and techniques necessary to de-energize electrical systems, identify live parts of equipment, and determine the nominal voltage of exposed live parts and clearance distances specified in Supplement 23.01.
- How to lock out and tag energized electrical circuits and equipment safely, as specified in Supplement 26.13.

- Other subjects, including
 - Electrical Safety Requirements for Employee Workplaces (NFPA 70E)
 - National Electrical Code (NFPA 70)
 - National Electrical Safety Code (ANSI/IEEE C2)
 - Use of personal protective grounds (29 CFR 1926.954(e))
 - Use of testing and measuring equipment (29 CFR 1910.334(c))
 - Work permit and work authorization procedures (FSPs and OSPs)
 - Use and care of personal protective equipment (29 CFR 1910.335(a))
 - Electrical safety in the work place (NFPA 70E)
 - Hazard categories and personnel requirements
 - The requirements of this chapter

Basic Hazards Control courses for non-electrical workers (see Section 23.6.2) should also be considered by supervisors to assist in qualifying electrical workers.

Refresher training for electrical workers is recommended at intervals not to exceed three years. This training shall include a formal review of current regulations and safety practices.

23.6.2 Non-Electrical Workers

The Occupational Safety and Health Administration requires training for individuals other than qualified electrical workers if their job assignments allow them to be close to exposed parts of electrical circuits operating at 50 V or more. Hazards Control offers the following courses for this purpose:

- HS5210, “Capacitor Safety Orientation”
- HS5220, “Electrical Hazards Awareness”
- HS5230, “High-Voltage Safety”
- HS5245, “Lock and Tag Procedure”
- HS5250, “Working on Energized R&D Equipment”

Refresher training in these courses and the regulations and codes listed in Section 23.6 is recommended every three years. This training shall include a formal review of current regulations and safety practices.

23.6.3 Supplementary Training

In addition to the courses offered by Hazards Control, both electrical workers and non-electrical workers whose job assignment requires them to work close to exposed electrical circuits operating at 50 V or more to ground (in accordance 29 CFR 1910.332) should receive training in the following areas as appropriate:

- The proper handling of portable tools and appliance cords.

- How to reset overcurrent protective devices.
- How to approach distances to overhead conductors.
- The meaning of electrical safety warnings and barriers.
- Electrical hazards associated with water.
- The proper response to electric shock.

For more detailed information on training requirements, see the LLNL *Training Program Manual* and the directorate training implementation plans.

23.7 LLNL Contacts

For guidance or further information regarding this chapter, contact the following as necessary:

- Employee's supervisor—General electrical concerns
- ES&H team industrial safety engineer—Specific concerns about electrical safety
- Industrial Safety/TSPD Division (ext. 3-5026)—Institutional electrical concerns
- Safety Training (ext. 2-5158)

23.8 Supporting References and Standards

ANSI/IEEE C2, *National Electrical Safety Code* (latest edition).

Charles F. Dalziel, "The Effects of Electric Shock on Man," *Industrial Radio Engineers Transactions on Medical Electronics* (May 1956).

Code of Federal Regulations, Title 29, Part 1910, Subpart I, "Personal Protective Equipment"; and Subpart S, "Electrical" (latest edition).

Code of Federal Regulations, Title 29, Part 1926, Subpart K, "Electrical"; and Subpart V, "Power Transmission and Distribution" (latest edition).

DOE/ID-10600, *Electrical Safety Guidelines* (May 1993).

Electronics Engineering Department, *Grounding Guidelines: Practical Examples for Power Systems at LLNL*, Lawrence Livermore National Laboratory, Livermore, CA (UCID-19752).

Illuminating Engineering Society, *IES Lighting Handbook* (latest edition).

NFPA 70, *National Electrical Code* (latest edition).

NFPA 70E, *Electrical Safety Requirements for Employee Workplaces* (latest edition).

NFPA 77, *Recommended Practice on Static Electricity* (latest edition).

NFPA 78, *Lightning Protection Code* (latest edition).

Ralph H. Lee, “Human Electrical Sheet” while an IEEE Fellow at E. I. duPont de Nemours & Co.; and “Electrical Safety in Industrial Plants,” in *IEEE Spectrum*, June 1971.

Appendix 23-A

Terms and Definitions

The following terms and acronyms are used in Chapter 23 and the supporting appendices.

affected employee	Any employee (including subcontractors) whose job requires him/her to operate or use a machine or work in an area where service or maintenance of equipment is being performed.
ac	Alternating current.
ANSI	American National Standards Institute.
authority having jurisdiction (AHJ)	Interprets the requirements of all electrical codes and standards such as the National Electrical Code (NFPA 70); the National Electrical Safety Code (ANSI/IEEE C2); 29 CFR 1910, Subpart S; 29 CFR 1926, Subparts K and V; and DOE Order 6430.1A, "General Design Criteria." Approves electrical equipment, wiring methods, electrical installations, and utilization of equipment for compliance.
authorized person	Any employee (including subcontractors) with acquired skills and training who has been approved or assigned by the supervisor to perform specific work or tasks.
bonding	The permanent joining of metallic parts to form an electrically conductive path that will ensure electrical continuity and the capacity to conduct safely any current likely to be imposed.
CFR	Code of Federal Regulations.
competent person	A person who is (1) capable of identifying existing and predictable hazards in work places; and (2) authorized and qualified by management to take prompt corrective measures to eliminate hazards, provide first aid, and notify the appropriate personnel when an accident or incident occurs.
CPR	Cardiopulmonary resuscitation.

dead-front construction	Electrical equipment built so that, in NEC 70 Article 100's definition, it is "without live parts exposed to a person on the operating side of the equipment." Article 384 (Switchboards and Panel Boards), in paragraph 384-3.(a), requires that: "Barriers shall be placed in all service switchboards that will isolate the service bussbars and terminals from the remainder of the switchboard."
dc	Direct current.
electrical equipment	A general term for material, fittings, devices, appliances, fixtures, apparatus, and the like that are used as a part of or in connection with an electrical installation. The term applies to both power-generation equipment and electronics equipment.
electrical hazard	Any situation in which an employee or any conductive tool or object in contact with the employee could contact or approach closer than the safe clearance distance of any live part or other energized conductor. Any situation in which electrical equipment is likely to cause a fire because of defective components or design. Examples of electrical hazards include inadequate working clearance while working on energized circuits, exposed energized parts, electrical equipment inadequately guarded or enclosed, electrical equipment in an unsafe environment, and unsafe electrical equipment. Generally, electrical equipment that is not in compliance with OSHA regulations or NEC standards presents a potential hazard.
facility power	Main disconnects, panel boards, switches, and associated wiring are considered facility/building power and are typically less than 600 V ac. These systems are designed and installed to operate facilities in these buildings (i.e., lighting, heating, air conditioning, or standby power supply and circuitry).
FSP	Facility safety procedure.

general supervisor

The person responsible for supervising and directing the work, and for ensuring the health and safety of workers. Specific responsibilities include

- Understanding potential hazards of the work.
- Ensuring that an employee is qualified by knowledge, training, and experience; that he/she has successfully demonstrated the ability to safely complete the work; and that the employee is authorized to perform the work.
- Having a complete understanding and the ability to reach agreement with the qualified person about the work to be performed, the sequence in which it should be done, and the potential and present hazards involved—having outlined those hazards and/or limitations of tasks to the extent considered necessary to ensure the worker's health and safety.

GFCI

Ground-fault circuit interrupter.

grounded

Connected to earth or to some conducting body that serves in place of the earth. Physically and intentionally connected to the earth through a ground connection of sufficient low impedance and with sufficient current-carrying capacity to prevent the buildup of voltages that may result in undue hazard to connected equipment or persons. (See ungrounded.)

joule (J)

Watt-second (power \times time); a unit of energy.

labeled

Equipment or materials to which a label, symbol, or other identifying mark has been applied by an NRTL.

listed

Equipment or materials included in a list published by an NRTL.

live/energized parts

The current edition of 29 CFR 1910 defines a "live part" as an electrically conducting part carrying more than 50 V ac or dc. (A part may be designated as "not live" if the current from the part to ground through 1500 Ω non-

	inductive resistance shunted by a capacitance of 0.15 μf cannot exceed 0.5 mA, even though the part carries voltage equal to or greater than that specified for a live part.)
lockout and/or tagout procedure	LLNL's general procedure for affixing appropriate locks and tags to energy-isolating devices to prevent inadvertent energizing or start-up of machines or equipment while service and maintenance is being performed. Lockout devices prevent the release of energy that could cause injury or death. Refer to Supplement 26.13 (LLNL Lockout and Tagout Program) of the <i>Health & Safety Manual</i> for details on this procedure.
minimum work distance or clearance	A minimum separation distance between a qualified electrical worker (or any conducting object touching the worker) and any energized component. Also, a mandatory separation distance between any energized component and vehicles or machinery. See Supplement 23.01 and 29 CFR 1910.303 and 1910.304.
NEC	National Electrical Code.
NEMA	National Electrical Manufacturers Association.
NFPA	National Fire Protection Association.
nationally recognized testing Laboratory (NRTL)	An organization that is concerned with product evaluation and maintains periodic inspection of listed equipment and materials. The NRTL ensures that the equipment or materials meet appropriate designated standards and that they have been tested and found to be suitable for use in a specified manner. (Refer to 29 CFR 1910.7, "Definition and Requirements for a Nationally Recognized Testing Laboratory.")
nominal system voltage	A nominal value assigned to a circuit or system to conveniently designate its voltage class (e.g., 120/240 V, 480Y/277 V, 600 V). The actual voltage at which a circuit operates can vary from the nominal within a range that permits satisfactory operation of the equipment. (Refer to ANSI C84.1, "Electric

	Power Systems and Equipment—Voltage Ratings [60 Hz]” for details.)
OJT	On-the-job training.
OSHA	Occupational Safety and Health Administration.
OSP	Operational safety procedure.
PPE	Personal protective equipment.
qualified person	A person who has been determined by his/her supervisor to have the skills, knowledge, and abilities to safely perform the work to which he/she is assigned. Qualifications may include a recognized degree, certificate, or professional standing—through extensive knowledge, training, and experience—or that one has successfully demonstrated the ability to resolve problems relating to the subject matter or work to the satisfaction of his/her supervisor.
safety watch	A person specifically assigned to stand by (within visible and audible range of workers) and continually monitor equipment and personnel for safety.
strain relief	A mechanical device that prevents force from being transmitted to the connections or terminals of a cable.
temporary wiring	Electrical wiring that is temporarily installed for a limited time to complete a specific task (e.g., construction of a new facility or performance of R&D work). Temporary wiring methods must apply sound engineering practices to ensure adequate electrical safety of temporary wiring installations. Temporary wiring shall conform to the requirements in Section 23.4.5 of this chapter, Article 305 of the NEC, and the respective subparts of 29 CFR 1910 and 1926.
ungrounded	A condition having no physical connection or continuity with earth ground. A condition of insulation or isolation. (See grounded.)

utility power

Utility, transmission, and distribution of electrical power systems typically above 600 V ac (i.e., substations, vaults, transformers, switch gear) prior to the final point of transformation and distribution. These electrical systems and equipment then furnish electrical power to buildings and facilities through an electric service entrance. Qualified Plant Engineering personnel (or their designees) are the *only* individuals authorized to work on these high-voltage systems.

Appendix 23-B

Effects of Electrical Energy on Humans

B.1 Physiological Effects

Electricity flowing through the human body can shock, cause involuntary muscle reaction, paralyze muscles, burn tissues and organs, or kill. The typical effects of various electric currents flowing through the body on the average 150-lb male and 115-lb female body are given in Table 23B-1.

Burns. Although a current may not pass through vital organs or nerve centers, internal electrical burns can still occur. These burns, which are a result of heat generated by current flowing in tissues, can be either at the skin surface or in deeper layers (muscles, bones, etc.), or both. Typically, tissues damaged from this type of electrical burn heal slowly.

Burns caused by electric arcs are similar to burns from high-temperature sources. The temperature of an electric arc, which is in the range of 4,000–35,000°F, can melt all known materials, vaporize metal in close proximity, and burn flesh and ignite clothing at distances up to 10 ft from the arc.

Delayed Effects. Damage to internal tissues may not be apparent immediately after contact with the current. Internal tissue swelling and edema are also possible.

Critical Path. The critical path of electricity through the body is through the chest cavity. At levels noted in Table 23B-1, current flowing from one hand to the other, from a hand to the opposite foot, or from the head to either foot will pass through the chest cavity paralyzing the respiratory or heart muscles, initiating ventricular fibrillation, and/or burning vital organs.

B.2 Biological Effects of Electrical Hazards

Influential Variables. The effects of electric current on the human body can vary depending on the following:

- Source characteristics (current, frequency, and voltage of all electric energy sources).
- Body impedance and the current's pathway through the body.
- How environmental conditions affect the body's contact resistance.
- Duration of the contact.

Table 23B-1. Effects of electric current on the human body. ^a

Effect/feeling	Direct current		Alternating current (mA)				Incident severity
	(mA)		60 Hz		10,000 Hz		
	150 lb	115 lb	150 lb	115 lb	150 lb	115 lb	
Slight sensation	1	0.6	0.4	0.3	7	5	None
Perception threshold	5.2	3.5	1.1	0.7	12	8	None
Shock not painful	9	6	1.8	1.2	17	11	None
Shock painful	62	41	9	6	55	37	Spasm, indirect injury
Muscle clamps source	76	51	16	10.5	75	50	Possibly fatal
Respiratory arrest	170	109	30	19	180	95	Frequently fatal
≥0.03-s vent. fibril.	1300	870	1000	670	1100	740	Probably fatal
≥3-s vent. fibril.	500	370	100	67	500	340	Probably fatal
≥5-s vent. fibril.	375	250	75	50	375	250	Probably fatal
Cardiac arrest	—	—	4000	4000	—	—	Possibly fatal
Organs burn	—	—	5000	5000	—	—	Fatal if it is a vital organ

^a See Ref. 1 at the end of this appendix.

Source Characteristics. An alternating current (ac) with a voltage potential greater than 550 V can puncture the skin and result in immediate contact with the inner body resistance. A 110-V shock may or may not result in a dangerous current, depending on the circuit path which may include the skin resistance. A shock greater than 600 V will always result in very dangerous current levels. The most severe result of an electrical shock is death.

Conditions for a serious (potentially lethal) shock across a critical path, such as the heart, are

1. More than 30-V root mean square (rms), 42.4-V peak, or 60 V dc at a total impedance of less than 5000 Ω .
2. 10 to 75 mA.
3. More than 10 J.

Conditions for a potentially lethal shock across the heart are

1. More than 375 V at a total body impedance of less than 5000 Ω ;
2. More than 75 mA; and
3. More than 50 J.

The worst possible frequency for humans is 60 Hz, which is commonly used in utility power systems. Humans are about five times more sensitive to 60-Hz alternating current than to direct current. At 60 Hz, humans are more

than six times as sensitive to alternating current than at 5000 Hz—and the sensitivity appears to decrease still further as the frequency increases. Above 100–200 kHz, sensations change from tingling to warmth, although serious burns can occur from higher radio-frequency energy.

At much higher frequencies (e.g., above 1 MHz), the body again becomes sensitive to the effects of an alternating electric current, and contact with a conductor is no longer necessary; energy is transferred to the body by means of electromagnetic radiation (EMR). For a discussion on the effects of EMR and the controls required for these sources, refer to Supplement 26.12 of the *Health & Safety Manual*.

Body Impedance. Three components constitute body impedance: internal body resistance and the two skin resistances at the contact points with two surfaces of different voltage potential. One-hand (or single-point) body contact with electrical circuits or equipment will prevent a person from completing a circuit between two surfaces of different voltage potential. Table 23B-2 provides a listing of skin-contact resistances encountered under various conditions. It also shows the work area surfaces and wearing apparel effects on the total resistance from the electrical power source to ground. This table can be used to determine how electrical hazards could affect a worker in varying situations.

Life-Threatening Effects. Charles F. Dalziel,¹ Ralph H. Lee,² and others have established the following criteria for the lethal effects of electric shock:

- Currents in excess of a human's "let-go" current (≥ 16 mA at 60 Hz) passing through the chest can produce collapse, unconsciousness, asphyxia, and even death (see also Table 23B-1).

Table 23B-2. Human resistance (Q) for various skin-contact conditions.^a

Body contact condition	Dry (Ω)	Wet (Ω)
Finger touch	40,000–1,000,000	4,000–15,000
Hand holding wire	15,000–50,000	3000–5000
Finger-thumb grasp	10,000–30,000	2000–5000
Hand holding a pliers	5,000–10,000	1000–3000
Palm touch	3000–8000	1000–2000
Hand around 1.5-in. pipe or drill handle	1000–3000	500–1500
Two hands around 1.5-in. pipe	500–1500	250–750
Hand immersed	—	200–500
Foot immersed	—	100–300

^a From Lee's "Electrical Safety in Industrial Plants" (see Ref. 2 in this appendix).

- Currents (≥ 30 mA at 60 Hz) flowing through the nerve centers that control breathing can produce respiratory inhibition, which could last long after interruption of the current.
- Cardiac arrest can be caused by a current greater than or equal to 1 A at 60 Hz flowing in the region of the heart.
- Relatively high currents (0.25–1 A) can produce fatal damage to the central nervous system.
- Currents greater than 5 A can produce deep body and organ burns, substantially raise body temperature, and cause immediate death.
- Delayed reactions and even death can be caused by serious burns or other complications.

The most dangerous current flow via the chest cavity is through the heart when the shock occurs in the time relative to the normal heart rhythm. This current may cause ventricular fibrillation, which is defined as repeated, rapid, uncoordinated contractions of the heart ventricles. Ventricular fibrillation that alters the heart's normal rhythmic pumping action can be initiated by a current flow of 75 mA or greater for 5 s or more through the chest cavity.

Probability of Ventricular Fibrillation. To determine the 5-s current flow (in mA) necessary to cause a 0.5% probability of ventricular-fibrillation, multiply a person's weight (in lb) by 0.49. To determine the 5-s current flow (in mA) necessary to cause a 99.5% probability of ventricular fibrillation, multiply a person's weight (in lb) by 1.47.

B.3 Determining How Much Current Is Passing Through a Body

Use the information in Tables 23B-1, 23B-2, and 23B-3 to project how electrical hazards could affect a worker in varying situations when protective equipment and apparel are in series with current flowing through a body. To determine how much current, I , is passing along a body path, use the formula $I = E/R$. The voltage, E , can be obtained by using an appropriate voltmeter. The total body resistance, R , can be determined by combining the appropriate resistance from Table 23B-2 with that from Table 23B-3.

Table 23B-3. Resistance values for equal areas (130 cm^2) of various work area materials.^a

Material	Resistance (Q)
Rubber gloves or soles	2.0×10^7
Dry concrete above grade	1.0×10^6 to 5.0×10^6
Dry concrete on grade	2.0×10^5 to 1.0×10^6
Leather sole, dry, including foot	1.0×10^5 to 5.0×10^5
Leather sole, damp, including foot	5.0×10^3 to 2.0×10^4
Wet concrete on grade	1.0×10^3 to 5.0×10^3

^a From Lee's "Electrical Safety in Industrial Plants" (see Reference 2 at the end of this appendix.)

References

1. Charles F. Dalziel, "The Effects of Electric Shock on Man," *Industrial Radio Engineers Transactions on Medical Electronics* (May 1956).
2. Ralph H. Lee, "Human Electrical Sheet" while an IEEE Fellow at E. I. duPont de Nemours & Co.; and "Electrical Safety in Industrial Plants," in *IEEE Spectrum*, June 1971.

Appendix 23-C

Electrical Equipment Compliance Criteria

The documents listed in this appendix provide compliance criteria for the design, installation, acceptance, operation, and maintenance of electrical equipment.

Table 23C-1. OSHA, ANSI, and DOE documents containing compliance criteria for electrical equipment.

Regulation, order, code, standard, or handbook	Title or description
29 CFR 1910, Subpart S (.301)	Electrical
29 CFR 1910.147	The control of hazardous energy (lockout/tagout); final rule
29 CFR 1910.268	Telecommunications
29 CFR 1926, Subpart K (.400)	Electrical [construction only]
29 CFR 1926, Subpart V (.950)	Power Transmission and Distribution [high voltage]
ANSI C2	The National Electrical Safety Code
ANSI/ISA-S82.01, .02, and .03	Safety Standard for Electrical and Electronic Test, Measuring, Controlling and Related Equipment
ANSI C73	American National Standard on Dimensions of Attachment Plugs [configuration tables for general-purpose nonlocking and locking plugs and receptacles]
ANSI C84.1	For Electric Power Systems and Equipment—Voltage Ratings (60 Hz)
ANSI Z136.1, Section 7	ANSI Standard for the Safe Use of Lasers [subsection 7.4, Electrical Hazards]
ANSI/IEEE Standard 18	IEEE Standard for Shunt Power Capacitors
ANSI/IEEE 80	IEEE Guide for Safety in AC Substation Grounding
DOE 6430.1A, Division 16	General Design Criteria for Electrical Design
DOE/EV/0051/1	Electrical Safety Requirements for R&D Activities
DOE/EV/06194 (latest revision)	<i>DOE Explosives Safety Manual</i>, Chapters 6, 7, and 8
DOE/ID-10600	Electrical Safety Guidelines
FIPS PUB 94	Guideline on Electrical Power for Automatic Data Processing Installations
IEEE 450	IEEE Recommended Practice for Maintenance, Testing, and Replacement of Large Lead Storage Batteries for Generating Stations and Substations

Table 23C-1. Cont'd.

Regulation, order, code, standard, or handbook	Title or description
IES Lighting Handbook	Illuminating Engineering Society's current application volume
NETA, International Electrical Testing Association, Inc.	Acceptance Testing Specifications for Electric Power Distribution Equipment and Systems
NFPA National Electrical Handbook	National Fire Protection Association's interpretations of current NFPA 70
NFPA 70	National Electrical Code
NFPA 70 B	Electrical Equipment Maintenance
NFPA 70 E	Electrical Safety Requirements for Employee Workplaces
NFPA 75	Electronic Computer/Data Processing Equipment
NFPA 77	Static Electricity
NFPA 78	Lightning Protection Code
NFPA 79	Electrical Standard for Industrial Machinery
NFPA 110 A	Stored Electrical Energy Emergency and Standby Power Systems